


PGE Reliability Area Power Quality Monitoring (Example)

Sag Events vs. SEMI F47 (Tool Ride-Through Standard)

Q3 2007
YTD



Note:
Metering Point may be at the substation. Therefore, voltage magnitudes are approximation of what is experienced at the customer site. ANSI C84.1 Utilization Voltage Lower Limit (87% of Nominal Voltage)

SARFI_{SEMI} = 0